

## WATER QUALITY TEST REPORT

Date Report : 25/07/2025

Report NO: WTR/2025/001

### School Details:

Name: R. M. P. Sports Academy

Address: Gurukul Narsan, Haridwar

### Samle Location:

Main Drinking Water Point (e.g. Ro Plant)

### Parameters Tested:

S. No	Parameter	Test Result	Permissible Limit	Remarks
1.	pH Value	7.1	6.5–8.5	Within Limit
2.	Total Dissolved Solids (TDS)	395mg/L	<500mg/L	Within Limit
3.	Hardness	135mg/L	<200mg/L	Within Limit
4.	Coliform Bacteria	Absent	Absent	Satisfactory

### Conclusion :

The water sample collected from the above site meets the BIS drinking water standards and is safe for consumption.

Authorized Signatory:

Name: Dr. Kuljeet Singh

Designation: Medical Officer

Seal and Signature: Kuljeet Singh

चिकित्सा अधिकारी  
सामुदायिक स्वास्थ्य केंद्र नारसन  
जनपद हरिद्वार